QA TEST REPORT

Request by	Arantxa
Tested by	Belinda
Purpose	Test the surface slip resistance according to AS4586:2013 standard
Date	2017-9-29

Tested samples

Specification	1213mm*176*5(1mm EVA-C)	**Structure**	Coating+ wear layer+ décor layer + rigid mineral+ balance paper
Coating	SE+UV Coating	**Color**	CW-237
Texture	Natural embossed	**Fixed/Unfixed**	Unfixed
Other	Batch No: B0081269724		

Test description: sample is washed with water and pH neutral detergent, rinsed with water, then dried.

Test Results

Specimen Number					**Average**
1	**2**	**3**	**4**	**5**	
30	**32**	**29**	**28**	**29**	**29.6**
Classification: P2					

Conclusion

The product meet P2 standard according to AS4586

New Classification	**BPN range Four S rubber**	**Existing classification**	**BPN range TRL rubber**	**Existing classification**
P0	<12	Part of Z	<12	-
P1	12-24	Part of Z	12-19	-
P2	24-34	Y	20-34	-
P3	35-44	X	35-39	-
P4	45-54	W	40-44	W
P5	>54	V	>44	V

Lab Tester: Belinda

Attachment:

